

Declaration of Performance

DOP 11/0437

1. Unique identification code of the product-type:

Pipe penetration seal „Floor Drain Fire Protection Set“

2. Product-type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4):

see list attached

3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:

To restore the permanent fire resistance of solid concrete floors penetrated by PP-HT pipes.

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):

**TECE GmbH
Hollefeldstraße 57
DE - 48282 Emsdetten
Phone +49 2572 928-0
info@tece.de**

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

not applicable

6. System or systems of assessment and verification of constancy of performance (AVCP) of the construction product as set out in Regulation (EU) No. 305/2011 (CPR), Annex V:

System 1 and System 3

7. In case of the declaration of performance concerning a construction product covered by a harmonised standard:

not applicable

8. In case of the declaration of performance concerning a construction product for which a European Technical Assessment (ETA) has been issued:

The notified body MPA Braunschweig, identification number 0761, performed the initial inspection of the manufacturing plant and in-house production control as well as the continual monitoring, assessment and evaluation of in-house production control in accordance with Systems 1 and 3 and issued the following:

- Certification of Conformity: No. 0761-CPD-0290 based on ETA-11/0437, in compliance with the regulation (EU) No. 305/2011 on the basis of European Assessment Document EAD 350454-00-1104 „Fire stopping and fire sealing products - Penetration seals“

The notified body MPA NRW, Testing Centre 0432 has classified the „Floor Drain Fire Protection Set K“ and issued the following:

- Classification report no. 210005767 MPA NRW

9. Declared performance:

Essential characteristics	Performance	Harmonised technical specification
Mechanical strength	NPD	ETA-11/0437
Fire behaviour (of product components):		
- Metal housing	A1	
- Calcium silicate plate „ROKU V2“	A2 – s1, d0	
- Flexible intumescent tape „ROKU Strip“	E	
- Flexible intumescent tape „Kerafix Flexterm 100“	E	
Fire resistance	EI 120-U/C	
Air and water permeability	NPD	
Emission of hazardous substances	none	
Safety in use	NPD	

Sound insulation	NPD	ETA-11/0437
Energy saving and thermal insulation	NPD	
Suitability and purpose	Type Z ₁ and Type Z ₂	

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.
This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:



Martin Krabbe, Head of Product Management and Development
Emsdetten, 22.7.2018



Ralf Sibum, Head of Testing and Approvals

Attachment to Declaration of Performance

DOP 11/0437

Product no.	Name (in ETA 11/0437)	Product
6 600 06	Floor Drain Fire Protection Set K	TECEdrainline Fire Protection Set Fire Stop EI 120 DN 50
369 00 50	Floor Drain Fire Protection Set DN 50	TECEdrainpoint S Fire Protection Set Fire Stop EI 120 DN 50



Martin Krabbe, Head of Product Management and Development
Emsdetten, 22.7.2018



Ralf Sibum, Head of Testing and Approvals